

## **SECTION 8**

### **8.02 HANDLING OF MATERIALS:**

Pipe and fittings shall be loaded and unloaded by lifting so as to avoid shock or damage. Under no circumstances shall such material be dropped. If, however, any part of the coating or lining is damaged, the replacement or repair of the damaged pipe shall be done to the satisfaction of Denver Water. Any pipe or fittings that are not acceptable to Denver Water shall be removed from the job site immediately. All pipe handling equipment and pipe handling methods shall be approved by Denver Water.